



Kangsabati Guchha Samity

Srirampur # Ratulia # Paschim Medinipur

General Water Quality Testing Laboratory under PHED Supported scheme of
Govt. of West Bengal.

Test results of Water Source

Name of School : G.D PUBLIC SCHOOL

T.W. Location : Vill - Chakralpur, P.O - Debra, Dist - Paschim Medinipur

T.W. Type : Submeesible

Sample Collection : 01.03.24

Testing Date: 01.03.24

a) Physico-chemical Parameters :

		<u>Desirable Limit</u>
pH	: 7.01	6.5-8.5
iron	: 0.01 mg / L	0.3 mg/L
Manganese	: 0.02 mg / L	0.3 mg/L
Total Hardness	: 116 mg / L	600 mg/L
TDS	: 555.9 mg/L	2000mg/L

b) Bacteriological Analysis :

MPN/100 ml : TC=0

FC=0

Shukdeb Das

Signature of NGO Official

General Secretary

Kangsabati Guchha Samity

Srirampur, Ratulia, Paschim Medinipur

Sandip Manna 12/03/24
Signature of Lab Personnel

Bacteriologist

Kangsabati Water Testing Lab
Srirampur, Ratulia, Paschim Medinipur